

HIGH SCHOOL

Sample Location		Results (parts per billion)		
Room	Device	Sept. 2016	Feb. 2017 A	Feb. 2017 B
Room 100	Faucet A	1.16		
Room 100	Faucet B	3.81		
Room 100	Faucet C	1.34		
Room 100	Faucet D	<1.0		
Room 100	Faucet E	1.53		
Room 100	Faucet F	1.55		
Room 100	Faucet H	2.41		
Room 100	Faucet I	2.45		
Room 100	Faucet J	1.54		
Room 100	Faucet K	<1.0		
Room 100	Faucet L	<1.0		
Room 100	Faucet M	<1.0		
Room 100	Faucet N	<1.0		
Room 100	Faucet O	<1.0		
Room 100	Faucet P	<1.0		
Room 100	Faucet Q	<1.0		
Room 101	Faucet A	<1.0		
Room 101	Faucet B	<1.0		
Room 101	Faucet C	3.89		
Room 101	Faucet D	2.37		
Room 101	Faucet E	3.53		
Room 101	Faucet F	<1.0		
Room 101	Faucet G	4.15		
Room 101	Faucet H	1.44		
Room 101	Faucet I	3.78		
Room 102	Faucet A	1.15		
Room 102	Faucet B	1.4		
Room 102	Faucet C	<1.0		
Room 102	Faucet D	1.38		
Room 102	Faucet E	1.19		
Room 102	Faucet F	1.14		

Room 102	Faucet G	1.05
Room 102	Faucet H	2.59
Room 105	Faucet B	3.32
Room 105	Faucet C	<1.0
Room 105	Faucet D	<1.0
Room 105	Faucet E	<1.0
Room 105	Faucet F	<1.0
Room 105	Faucet G	<1.0
Room 105	Faucet H	<1.0
Room 105	Faucet I	<1.0
Room 105	Faucet J	<1.0
Room 105	Faucet K	1.33
Room 105	Faucet L	20.8 Lab Faucet-Not re-tested per new guidance from NYSED
Room 105	Faucet M	1.37
Room 107	Faucet	8
Room 108	Faucet B	2.6
Room 108	Faucet C	1.01
Room 108	Faucet D	1.1
Room 108	Faucet E	1.72
Room 108	Faucet F	9.05
Room 108	Faucet G	2.61
Room 108	Faucet H	1.52
Room 108	Faucet I	1.7
Room 111	Faucet A	7.67
Room 111	Faucet B	15.2 Lab Faucet-Not re-tested per new guidance from NYSED
Room 111	Faucet C	19.2 Lab Faucet-Not re-tested per new guidance from NYSED
Room 111	Faucet D	5.39
Room 111	Faucet E	5.84
Room 111	Faucet F	4.15
Room 111	Faucet G	10.3
Room 111	Faucet H	1.97
Room 112	Faucet A	5.54
Room 112	Faucet B	8.9
Room 112	Faucet C	<1.0

Room 112	Faucet D	<1.0			
Room 112	Faucet E	<1.0			
Room 112	Faucet F	<1.0			
Room 112	Faucet G	<1.0			
Room 112	Faucet H	<1.0			
Room 112	Faucet I	<1.0			
Room 112	Faucet J	<1.0			
Room 112	Faucet K	<1.0			
Room 112	Faucet L	<1.0			
Room 112	Faucet M	<1.0			
Room 112	Faucet N	<1.0			
Room 112	Faucet O	<1.0			
Room 112	Faucet P	<1.0			
Room 113	Faucet	1.03			
Room 115	Faucet B	<1.0			
Room 115	Faucet C	1.08			
Room 117	Faucet A	1.99			
Room 117	Faucet B	1.11			
Room 117	Faucet C	1.18			
Room 117	Faucet D	2.72			
Room 117	Faucet E	7.08			
Library	Faucet 1A	<1.0			
Library	Faucet 1	1.26			
Library	Faucet 2	7.33			
Guidance Office-Kitchenette	Faucet	1.26			
Registrar's Office	Faucet	4.78			
Registrar's Office - Lav	Faucet	2.41			
Women's Lav - by Auditorium	Faucet	4.71			
Men's Lav - by Auditorium	Faucet	8.16			
Psychologist's Office	Faucet	72.7	42.1	11.6	0
Main Office	Faucet	<1.0			
Main Corridor (next to 111)	Fountain 2	1.63			
Main Corridor (across from 112)	Fountain 3	1.57			
Main Corridor (across from Library)	Fountain 4	<1.0			

Corridor (outside Guidance Off)	Fountain 5	10.2
2nd Floor Corridor (next to 206)	Fountain 6	1.08
2nd Floor Corridor (next to 220)	Fountain 7	1.78
2nd Floor Corridor (next to 217)	Fountain 8	2.21
2nd Floor Corridor (across from 206)	Fountain 9	1.45
2nd Floor Corridor (next to 203)	Fountain 10	<1.0
Auditorium Lobby (upper)	Fountain 11	<1.0
Auditorium Lobby (lower)	Fountain 12	<1.0
Chemical Storage Room	Faucet	1.84
Faculty Room-Main Corridor- HSN	Faucet	<1.0
Men's Lav N - Fac Rm-Main Corridor	Faucet 1	<1.0
Women's Lav N - Fac Rm-Main Corridor	Faucet 1	<1.0
Men's Faculty Lav- by 228	Faucet 2	5.36
Women's Faculty Lav - by 228	Faucet 2	7.48
Women's Faculty Lav - by Guidance Off	Faucet 3	2.32
Men's Faculty Lav- by Guidance Off	Faucet 3	2.75
Boy's Lav - across from 102	Faucet 1	3.21
Girl's Lav - across from Library	Faucet 1	4.73
Girl's Lav - by 207	Faucet 2	4.25
Boy's Lav by 204	Faucet 2	32.5 Mixing valve-Not retested per new guidance from NYSED
Room 204	Faucet	3.34
Room 207	Faucet	14
Room 214	Faucet	1.66
Room 216	Faucet	4.89
Room 212	Faucet A	<1.0
Room 212	Faucet B	<1.0
Room 212	Faucet C	<1.0
Room 212	Faucet D	1.68
Room 212	Faucet E	1.06
Room 212	Faucet F	10.5
Room 118	Faucet A	31 Lab Faucet-Not re-tested per new guidance from NYSED
Room 118	Faucet B	15.9 Lab Faucet-Not re-tested per new guidance from NYSED
Room 118	Faucet C	24.9 Lab Faucet-Not re-tested per new guidance from NYSED
Room 118	Faucet D	5.72

Room 118	Faucet E	3.86
Room 118	Faucet F	4.03
Room 118	Faucet G	4.67
Room 118	Faucet H	4.11
Room 118	Faucet I	3.22
Room 118	Faucet J	4.14
Room 118	Faucet K	5.86
Room 118	Faucet L	2.64
Room 118	Faucet M	3.61
Room 118	Faucet N	3.18
Room 118	Faucet O	3.62
Room 118	Faucet P	54.2 Lab Faucet-Not re-tested per new guidance from NYSED
Room 120	Faucet A	21.7 Lab Faucet-Not re-tested per new guidance from NYSED
Room 120	Faucet B	99.2 Lab Faucet-Not re-tested per new guidance from NYSED
Room 120	Faucet C	58.8 Lab Faucet-Not re-tested per new guidance from NYSED
Room 120	Faucet D	2.8
Room 120	Faucet E	2.07
Room 120	Faucet F	4.88
Room 120	Faucet G	5.95
Room 120	Faucet H	4.3
Room 120	Faucet I	4.12
Room 120	Faucet J	4.86
Room 120	Faucet K	7.11
Room 120	Faucet L	3.56
Room 120	Faucet M	3360 Lab Faucet-Not re-tested per new guidance from NYSED
Room 120	Faucet N	5.15
Room 120	Faucet O	5.25
Room 120	Faucet P	37.6 Lab Faucet-Not re-tested per new guidance from NYSED
Corridor (across from 118)	Fountain	<1.0
Girl's Lav (2nd Floor-across from 256)	Faucet A	1.28
Girl's Lav (2nd Floor-across from 256)	Faucet B	6.48
Girl's Lav (2nd Floor-across from 256)	Faucet C	7.06
Girl's Lav (2nd Floor-across from 256)	Faucet D	10.8
Boy's Lav (2nd Floor-across from 254)	Faucet A	14.6

Boy's Lav (2nd Floor-across from 254)	Faucet B	9.41	
Boy's Lav (2nd Floor-across from 254)	Faucet C	11	
Boy's Lav (2nd Floor-across from 254)	Faucet D	9.4	
Corridor (2nd Floor-across from 254)	Fountain	4.4	
Corridor (next to 156)	Fountain	1.54	
Corridor (across from Athletic Office)	Fountain	9.77	
Corridor (across from 150)	Fountain	3.46	
Corridor (next to 153)	Fountain	3.01	
Corridor (next to 157)	Fountain	3.8	
Corridor (by south gym)	Fountain	Fountain removed	
Corridor (next to Superintendent's Office)	Fountain	<1.0	
Corridor (across from 162)	Fountain	3.1	
Corridor (by Girl's Lav across from 164)	Fountain	2.77	
Corridor (next to 165)	Fountain	6.66	
Corridor (by 2nd Floor Girl's Lav acr 272)	Fountain	3.36	
Corridor (by 2nd Floor Boy's Lav acr 270)	Fountain	<1.0	
Corridor (2nd Floor, across from 278)	Fountain	6.22	
Corridor (2nd Floor, across from 256)	Fountain	2.54	
Girl's Lav (2nd Floor, across from 270)	Faucet 2A	9.22	
Girl's Lav (2nd Floor, across from 270)	Faucet 2B	16.2	4.5
Girl's Lav (2nd Floor, across from 270)	Faucet 2C	6.69	
Boy's Lav (2nd Floor, across from 270)	Faucet 2A	12.1	
Boy's Lav (2nd Floor, across from 270)	Faucet 2B	12.2	
Boy's Lav (2nd Floor, across from 270)	Faucet 2C	3.43	
Superintendent's Lunch Room	Faucet	21.1	9.64
Faculty Lounge (across from 160)	Faucet 1	4.92	
Faculty Lounge (2nd Floor, next to 262)	Faucet 2	19.2	4.63
Nurse's Office	Faucet 1	8.35	
Nurse's Office	Faucet 2	10.9	
Business Office Lave	Faucet	14.1	
Business Office Lunch Room	Faucet	12.5	
Nurse's Office Lav	Faucet	4.85	
Athletic's Office	Faucet	23.2	7.13
Superintendent's Lav	Faucet	12.6	

Faculty Room by south boiler room	Faucet	35.6	35.7	35.7	1.2
Men's Lav (across from 150)	Faucet A	1050	6.26		
Men's Lav (across from 150)	Faucet B	62.3	10.2		
Men's Lav (across from 150)	Faucet C	62.9	3.16		
Men's Lav (across from 150)	Faucet D	13.1			
Boy's PE Director	Faucet	29.6	4.68		
Girl's PE Director	Faucet	11			
Gym Lav - Women's	Faucet	2.57			
Gym Lav - Men	Faucet	4.4			
Men's Lav (by south loading dock)	Faucet	2.26			
Women's Lav (by south loading dock)	Faucet	<1.0			
Women's Lav (by south loading dock)	Faucet	1.71			
Boy's Locker Room (south)	Faucet	11.4			
Girl's Locker Room (south)	Faucet	7.72			
Student Services Conference Room	Faucet	4.11			
Boy's Lav (across from 162)	Faucet A	10.8			
Boy's Lav (across from 162)	Faucet B	10.1			
Boy's Lav (across from 162)	Faucet C	6.25			
Girl's Lav (across from 162)	Faucet A	7.28			
Girl's Lav (across from 162)	Faucet B	11.2			
Educational Support Office	Faucet	4.06			
Faculty Lounge Men's Lav (acr 160)	Faucet	5.87			
Faculty Lounge Men's Lav (next to 262)	Faucet	7.15			
Faculty Lounge Women's Lav (acr 160)	Faucet	5.94			
Fac Lounge Women's Lav (next to 262)	Faucet	6.91			
Educational Support Men's Lav	Faucet	9.91			
Educational Support Women's Lav	Faucet	4.14			
Room 150	Faucet	9.32			
Room 151	Faucet A	2.39			
Room 151	Faucet B	2.22			
Room 151 -Dark Room	Faucet	17.4	Lab Faucet-Not re-tested per new guidance from NYSED		
Room 153	Faucet	4.83			
Room 154	Faucet	24.8	11		
Room 155	Faucet A	7.66			

Room 155	Faucet B	9.59	
Room 157	Faucet A	2.48	
Room 157	Faucet B	2.45	
Room 167	Faucet	35.1	9.02
Room 263	Faucet	27.9	5.33
Room 301	Faucet	<1.0	
Band Room	Faucet	2.75	
Boy's Locker Room (north)	Faucet 2	<1.00	
Boy's Locker Room (north)	Faucet 1	<1.00	
Girl's Locker Room (north)	Faucet 1	<1.00	
Girl's Locker Room (north)	Faucet 2	<1.00	
Girl's PE Coach/Teacher Lav	Faucet	3.6	
Boy's PE Coach/Teacher Lav	Faucet	1.61	
Men's Dressing Room	Faucet	<1.00	
Women's Dressing Room	Faucet	<1.00	
Boy's Lav (by Cafeteria)	Faucet 1	11.5	
Boy's Lav (by Cafeteria)	Faucet 2	13.5	
Girl's Lav (by Cafeteria)	Faucet 1	7.51	
Girl's Lav (by Cafeteria)	Faucet 2	12.4	
Kitchen	Faucet 1	1.48	
Kitchen	Faucet 2	<1.00	
Kitchen	Faucet 3	1.79	
Kitchen	Faucet 4	1.65	
Kitchen	Faucet 5	2.56	
Kitchen	Faucet 6	<1.00	
Cafeteria	Faucet 7	1.1	
Kitchen (steam pot sink)	Faucet	<1.00	
Staff Lav (kitchen)	Faucet	1.52	
Corridor (across from boiler room)	Fountain 13	2.37	
Corridor (across from auxillary gym)	Fountain 14	2.66	
Corridor (across from cafeteria)	Fountain 15	<1.00	
Cafeteria	Fountain 16	1.3	
Cafeteria	Fountain 17	3.11	
Chorus Room	Fountain 18	<1.00	

Band Room	Fountain 19	<1.00			
Pool Deck	Fountain	<1.00			
Girl's Locker Room (pool)	Fountain	<1.01			
Boy's Locker Room (pool)	Fountain	<1.02			
Maintenance Building	Fountain	<1.03			
Kitchen	Ice Machine	<1.00			
	Total Tested	205	13	2	2
	Total >15	27	2	1	0