

MIDDLE SCHOOL

Sample Location		Results (parts per billion)	
Room	Device	Sept. 2016	Feb. 2017
Girl's Lav (across from 217)	Faucet A	7.08	
Girl's Lav (across from 217)	Faucet B	5.56	
Girl's Lav (across from 217)	Faucet C	6.19	
Girl's Lav (across from 217)	Faucet D	4.57	
ADA Accessible Lav (by language office)	Faucet	9.86	
Faculty Room (across from 100)	Faucet	1.46	
Faculty/Copy Room (across from 221)	Faucet	34.5	4.3
Women's Faculty Lav (across from 111)	Faucet	3.1	
Men's Faculty Lav (across from 113)	Faucet 1	3.85	
Women's Faculty Lav (next to 208)	Faucet 2	1.64	
Men's Faculty Lav (next to 208)	Faucet 2	4.67	
Women's Faculty Lav (across from 217)	Faucet 3	3.86	
Men's Faculty Lav (across from 217)	Faucet 3	2.94	
Room 199	Faucet	2.21	
Room 101	Faucet	1.21	
Room 106A	Faucet	2.14	
Room 116	Faucet A	3.7	
Room 116	Faucet B	4.61	
Room 118	Faucet A	4.23	
Room 118	Faucet B	3.75	
Room 125	Faucet	1.93	
Room 129	Faucet	17.2	1.3
Room 219	Faucet A	34.6	Lab Faucet-Not re-tested per new guidance from NYSED
Room 219	Faucet B	78.5	Lab Faucet-Not re-tested per new guidance from NYSED
Room 219	Faucet C	35.2	Lab Faucet-Not re-tested per new guidance from NYSED
Room 219	Faucet D	44.1	Lab Faucet-Not re-tested per new guidance from NYSED
Room 219	Faucet E	18.2	Lab Faucet-Not re-tested per new guidance from NYSED
Room 219	Faucet F	18.9	Lab Faucet-Not re-tested per new guidance from NYSED
Room 219	Faucet G	24.5	Lab Faucet-Not re-tested per new guidance from NYSED
Room 219	Faucet F	25.2	Lab Faucet-Not re-tested per new guidance from NYSED
Nurse's Office	Faucet 1	2.05	

Nurse's Office	Faucet 2	14.8	
Main Office Men's Lav	Faucet	8.7	
Main Office Women's Lav	Faucet	2.71	
Main Office	Fountain	2.32	
Corridor (between 199 and 101)	Fountain	<1.0	
Corridor (across from 111)	Fountain	<1.0	
Corridor (across from 121)	Fountain	1.4	
Corridor (across from 127)	Fountain	1.12	
Corridor (across from 211)	Fountain	1.1	
Corridor (across from 217)	Fountain	3.75	
Boys Lav (across from 217)	Faucet A	8.71	
Boy's Lav (across from 113)	Faucet B	5.8	
Boy's Lav (across from 113)	Faucet C	5.38	
Boy's Lav (across from 113)	Faucet D	3.61	
Boy's Lav (by 208)	Faucet A	1.18	
Boy's Lav (by 208)	Faucet B	8.2	
Boy's Lav (by 208)	Faucet C	8.81	
Boy's Lav (by 208)	Faucet D	7.55	
Boy's Lav (across from 217)	Faucet A	1.26	
Boy's Lav (across from 217)	Faucet B	6.6	
Boy's Lav (across from 217)	Faucet C	5.96	
Boy's Lav (across from 217)	Faucet D	4.65	
Girl's Lav (across from 111)	Faucet B	1.95	
Girl's Lav (across from 111)	Faucet C	6.75	
Girl's Lav (across from 111)	Faucet D	78.4	0.9
Girl's Lav (by 208)	Faucet A	8.37	
Girl's Lav (by 208)	Faucet B	2.89	
Girl's Lav (by 208)	Faucet C	2.7	
Girl's Lav (by 208)	Faucet D	2.56	
Room 219	Faucet I	22.4	Lab Faucet-Not re-tested per new guidance from NYSED
Room 217	Faucet B	23.9	Lab Faucet-Not re-tested per new guidance from NYSED
Room 217	Faucet C	55.6	Lab Faucet-Not re-tested per new guidance from NYSED
Room 217	Faucet D	54.1	Lab Faucet-Not re-tested per new guidance from NYSED
Room 217	Faucet E	61.8	Lab Faucet-Not re-tested per new guidance from NYSED

Room 217	Faucet F	64.8	Lab Faucet-Not re-tested per new guidance from NYSED
Room 217	Faucet H	252	Lab Faucet-Not re-tested per new guidance from NYSED
Room 217	Faucet I	101	Lab Faucet-Not re-tested per new guidance from NYSED
Room 216	Faucet A	29.7	1.1
Room 216	Faucet B	48.9	0.6
Room 216	Faucet C	48.2	0.8
Room 216	Faucet D	47.9	1.2
Room 216	Faucet E	39.2	0.6
Room 216	Faucet F	9.63	
Room 215	Faucet A	96.9	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet B	46.4	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet C	61.2	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet D	49.7	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet E	42.1	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet F	60.4	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet G	51.8	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet H	37.4	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet I	23.2	Lab Faucet-Not re-tested per new guidance from NYSED
Room 215	Faucet J	65.8	Lab Faucet-Not re-tested per new guidance from NYSED
Room 214	Faucet	15.3	0.8
Room 221	Faucet	2.15	
Room 227	Faucet	46.8	8.3
Corridor (by 218)	Fountain	2.48	
Room 209	Faucet A	15.4	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet B	37	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet C	52.1	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet D	49.8	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet E	65.5	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet F	62.8	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet G	33.3	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet H	23.8	Lab Faucet-Not re-tested per new guidance from NYSED
Room 209	Faucet I	18.4	Lab Faucet-Not re-tested per new guidance from NYSED
Dark Room	Faucet	21.9	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet A	36.6	Lab Faucet-Not re-tested per new guidance from NYSED

Room 211	Faucet B	37.2	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet C	25.3	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet D	27.2	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet E	54.5	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet F	23.4	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet G	25.5	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet H	27.5	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet I	120	Lab Faucet-Not re-tested per new guidance from NYSED
Room 211	Faucet J	25.5	Lab Faucet-Not re-tested per new guidance from NYSED
Room 213	Faucet B	22.4	Lab Faucet-Not re-tested per new guidance from NYSED
Room 213	Faucet C	37.2	Lab Faucet-Not re-tested per new guidance from NYSED
Room 213	Faucet D	64.9	Lab Faucet-Not re-tested per new guidance from NYSED
Room 213	Faucet E	56.9	Lab Faucet-Not re-tested per new guidance from NYSED
Room 213	Faucet H	91.9	Lab Faucet-Not re-tested per new guidance from NYSED
Room 213	Faucet F	53.1	Lab Faucet-Not re-tested per new guidance from NYSED
	Total Tested	112	10
	Total >15	62	0