

## RIDGE ROAD

Room	Sample Location	Device	Results (parts per billion)	
			Sept 2016	Feb 2016
Kitchen		Faucet 1	4	
Kitchen		Faucet 2	35	1.3
Kitchen		Faucet 3	9.3	
Corridor (across from 130)		Fountain	4.2	
Corridor (across from 128)		Fountain	4.4	
Corridor (next to 126)		Fountain	7	
Corridor (next to 123)		Fountain	8.8	
Corridor (next to music room-ADA)		Fountain	<1	
Corridor (next to music room-upper)		Fountain	<1	
Corridor (across from Gym)		Fountain	4.5	
Cafeteria		Fountain	<1	
Corridor (next to Nurse's office)		Fountain	2.3	
PE Teacher Lav		Fountain	4.1	
Main Office Conference Room		Faucet	2.2	
Faculty Lounge (next to Gym)		Faucet	2.6	
Faculty Lounge (across from 103)		Faucet	2.5	
Nurses Office		Faucet 1	9.8	
Nurses Office (in Lav)		Faucet 2	1.7	
Girl's Lav (across from 130)		Faucet	4.4	
Boy's Lav (across from 128)		Faucet	6.1	
Girl's Lav (next to 115)		Faucet	9	
Boy's Lav (across from 115)		Faucet	7.3	
Room 103		Faucet	7.8	
Room 103		Bubbler	2.8	
Room 104		Faucet	<1	
Room 104		Bubbler	1.5	
Room 105		Faucet	9	
Room 105		Bubbler	3.8	
Room 106		Faucet	9.6	
Room 106		Bubbler	2	
Room 107		Faucet	4.7	
Room 107		Bubbler	<1	
Room 108		Faucet	7	
Room 108		Bubbler	1.5	
Room 109		Faucet	8.8	
Room 109		Bubbler	3.7	
Room 114		Faucet	1.4	
Room 114		Bubbler	1.3	
Room 115		Faucet	9.1	
Room 115		Bubbler	5.3	
Room 116		Bubbler	1.4	
Room 117		Faucet	19	2.8
Room 118		Faucet A	4.2	
Room 118		Faucet B	5.2	

Room 118	Faucet C	6.9	
Room 119	Faucet	17	0.5
Room 121	Faucet	6	
Room 122	Faucet	11	
Room 124	Faucet	7.4	
Room 125	Faucet	5.8	
Room 126	Faucet	10	
Room 127	Faucet	7.6	
Room 128	Faucet	4.2	
Room 129	Faucet	4.6	
Room 130	Faucet	18	1.1
Room 131	Faucet	3.2	
Room 132	Faucet	9.1	
Room 133	Faucet	4.4	
Room 134	Faucet	6	
Room 136	Faucet	8.6	
	<b>Total Tested</b>	60	4
	<b>Total &gt;15</b>	4	0