

## Gardner Road Elementary School - Water Testing Summer 2021

Sample Identification	Description	Initial Results	Results After Remediation
311A	Classroom - Draw 1	7.5	
311B	Classroom - Draw 2	1.6	
306A	Classroom - Draw 1	6.3	
306B	Classroom - Draw 2	<1.0	
304A	Classroom - Draw 1	6.1	
304B	Classroom - Draw 2	<1.0	
309A	Classroom - Draw 1	4.3	
309B	Classroom - Draw 2	1.6	
CBA1	Boys Lav by 307	2.4	
CBA2	Boys Lav by 307	4.6	
CBB1	Boys Lav by 307	1.6	
CBB2	Boys Lav by 307	1.5	
CBC-1	Boys Lav by 307	11.6	
CBC-2	Boys Lav by 307	1.8	
CGA1	Girls Lav by 307	6.5	
CGA2	Girls Lav by 307	4.5	
CGB-1	Girls Lav by 307	4.3	
CGB-2	Girls Lav by 307	5.7	
CGC1	Girls Lav by 307	2.1	
CGC2	Girls Lav by 307	3.0	
FMC1	Mens Faculty Lav by 307	2.2	
FMC2	Mens Faculty Lav by 307	1.3	
FWC1	Women's Faculty Lav by 307	2.0	
FWC2	Women's Faculty Lav by 307	1.4	
307A	Classroom - Draw 1	6.9	
307B	Classroom - Draw 2	<1.0	
305A	Classroom - Draw 1	5.5	
305B	Classroom - Draw 2	<1.0	
302A	Classroom - Draw 1	6.6	
302B	Classroom - Draw 2	<1.0	
BOT1A	Bottle Filler by Gym - Draw 1	2.6	

BOT1B	Bottle Filler by Gym - Draw 2	3.4	
BL1A	Boys Lav by Gym - Draw 1	20.9	17.7
BL1B	Boys Lav by Gym - Draw 2	20.4	9.8
GL2A	Girls Lav by Gym - Draw 1	18.5	13.8
GL2B	Girls Lav by Gym - Draw 2	24.0	21
PE1A	PE Office - Draw 1	9.5	
PE1B	PE Office - Draw 2	1.4	
BOT4A	Bottle Filler - Cafeteria - Draw 1	<1.0	
BOT4B	Bottle Filler - Cafeteria - Draw 2	<1.0	
209A	Classroom - Draw 1	5.8	
209B	Classroom - Draw 2	<1.0	
206A	Classroom - Draw 1	7.4	
206B	Classroom - Draw 2	1.1	
207A	Classroom - Draw 1	8.0	
207B	Classroom - Draw 2	<1.0	
204A	Classroom - Draw 1	4.3	
204B	Classroom - Draw 2	<1.0	
BPA1	Boys Lav by 205 - Draw 1	2.7	
BPA2	Boys Lav by 205 - Draw 2	2.3	
BBB1	Boys Lav by 205 - Draw 1	3.6	
BBB2	Boys Lav by 205 - Draw 2	2.4	
BBC1	Boys Lav by 205 - Draw 1	3.5	
BBC2	Boys Lav by 205 - Draw 2	2.3	
BGA1	Girls Lav by 205 - Draw 1	3.0	
BGA2	Girls Lav by 205 - Draw 2	1.9	
BGB1	Girls Lav by 205 - Draw 1	2.8	
BGB2	Girls Lav by 205 - Draw 2	2.0	
BGC1	Girls Lav by 205 - Draw 1	3.5	
BGC2	Girls Lav by 205 - Draw 2	2.1	
FMB1	Mens Faculty Lav by 205 - Draw 1	7.9	
FMB2	Mens Faculty Lav by 205 - Draw 2	1.2	
FWB1	Women's Faculty Lav by 205 - Draw 1	3.1	
FWB2	Women's Faculty Lav by 205 - Draw 2	3.8	

\*these faucets are on mixing valves and not required to be tested. They are posted as non-potable faucets

205A	Classroom - Draw 1	4.7	
205B	Classroom - Draw 2	<1.0	
203A	Classroom - Draw 1	10.0	
203B	Classroom - Draw 2	<1.0	
BWFL1	B Wing Workroom - Draw 1	8.6	
BWFL2	B Wing Workroom - Draw 2	<1.0	
202A	Classroom - Draw 1	6.0	
202B	Classroom - Draw 2	<1.0	
200A	Classroom - Draw 1	6.8	
200B	Classroom - Draw 2	<1.0	
LIB1A	Library	6.3	
LIB1B	Library	<1.0	
LIB2A	Library	13.6	
LIB2B	Library	<1.0	
CORBL1	Boy's Lav, Main Corridor - Draw 1	3.0	
CORBL2	Boy's Lav, Main Corridor - Draw 2	<1.0	
CORWL1	Girls Lav, Main Corridor - Draw 1	3.8	
CORWL2	Girls Lav, Main Corridor - Draw 2	<1.0	
MO1A	Main Office Break Room - Draw 1	7.7	
MO1B	Main Office Break Room - Draw 2	<1.0	
NUR01	Nurses Office - Draw 1	4.0	
NUR02	Nurses Office - Draw 2	<1.0	
NUR L1	Nurses Lav - Draw 1	3.1	
NUR L2	Nurses Lav - Draw 2	<1.0	
100A	Classroom - Draw 1	8.5	
100B	Classroom - Draw 2	<1.0	
102A	Classroom - Draw 1	1.6	
102B	Classroom - Draw 2	<1.0	
104A	Classroom - Draw 1	2.6	
104B	Classroom - Draw 2	<1.0	
114A	Classroom - Draw 1	6.4	
114B	Classroom - Draw 2	<1.0	
115A	Classroom - Draw 1	5.5	

115B	Classroom - Draw 2	2.8	
113A	Classroom - Draw 1	2.5	
113B	Classroom - Draw 2	<1.0	
112A	Classroom - Draw 1	5.3	
112B	Classroom - Draw 2	<1.0	
111A	Classroom - Draw 1	3.4	
111B	Classroom - Draw 2	<1.0	
110A	Classroom - Draw 1	27.1	5.6
110B	Classroom - Draw 2	3.1	
109A	Classroom - Draw 1	7.3	
109B	Classroom - Draw 2	<1.0	
108A	Classroom - Draw 1	4.4	
108B	Classroom - Draw 2	<1.0	
107A	Classroom - Draw 1	5.1	
107B	Classroom - Draw 2	<1.0	
106A	Classroom - Draw 1	2.1	
106B	Classroom - Draw 2	<1.0	
AWFL1	A-wing Faculty Room - Draw 1	4.1	
AWFL2	A-wing Faculty Room - Draw 2	<1.0	
AFLAV1	A-wing Faculty Room Lav- Draw 1	1.3	
AFLAV2	A-wing Faculty Room Lav- Draw 2	<1.0	
BOT5A	Bottle Filler, Main Corridor - Draw 1	<1.0	
BOT5B	Bottle Filler, Main Corridor - Draw 2	<1.0	
ART11	Art Room - Draw 1	3.9	
ART12	Art Room - Draw 2	<1.0	
ART21	Art Room - Draw 1	5.3	
ART22	Art Room - Draw 2	<1.0	
ART31	Art Room - Draw 1	5.0	
ART32	Art Room - Draw 2	<1.0	
ART41	Art Room - Draw 1	3.6	
ART42	Art Room - Draw 2	<1.0	
PSY 1	Psychologist Office - Draw 1	6.6	
PSY 2	Psychologist Office - Draw 2	<1.0	

CUST 1A	Custodial Office Lav - Draw 1	4.6	
CUST 1B	Custodial Office Lav - Draw 2	<1.0	
KIT 1A	Kitchen - Draw 1	152	4.7
KIT 1B	Kitchen - Draw 2	2.8	
KIT 2A	Kitchen - Draw 1	39.3	5.4
KIT 2B	Kitchen - Draw 2	3.6	
POT1A	Kitchen, Steam Pot - Draw 1	7.0	
POT1B	Kitchen, Steam Pot - Draw 2	<1.0	
KIT 3A	Kitchen - Draw 1	6.7	
KIT 3B	Kitchen - Draw 2	<1.0	
KIT 4A	Kitchen - Draw 1	1.9	
KIT 4B	Kitchen - Draw 2	<1.0	
KIT 5A	Kitchen - Draw 1	4.5	
KIT 5B	Kitchen - Draw 2	<1.0	
KIT LA	Kitchen Lav - Draw 1	4.9	
KIT LB	Kitchen Lav - Draw 2	<1.0	

NYSDOH Action Level for Lead of 15 ppb